

Did you know....

Your water can become contaminated if connections to your plumbing system are not properly protected!

The purpose of the local Cross-Connection Control Program, as required by State Plumbing Code and Regulations, is to ensure that everyone in the community has safe, clean drinking water.

Public Health & Safety....

To avoid contamination, backflow preventers are required by state plumbing codes wherever there is an actual or potential hazard for a cross-connection. The Wisconsin Department of Natural Resources requires all public water suppliers to maintain an on-going Cross-Connection Control Program involving public education, onsite inspections, and possible corrective actions by building owners if required.

More Information


WI Dept. of Natural Resources
www.dnr.wi.gov

Environmental Protection Agency
www.epa.gov

WI Dept. of Safety & Professional Services
www.dsps.wi.gov



Village of Random Lake
96 Russell Drive
P.O. Box 344
Random Lake, WI 53075
Phone: (920) 994-4852
Fax: (920) 994-2390



**Residential Water User
Cross-Connection
Hazards**

Bathrooms & Kitchens



What is Cross Connection?

A cross connection is an actual or potential connection between the safe drinking water (potable) supply and source of contamination or pollution. State plumbing codes require approved backflow prevention devices, assemblies, or the methods to be installed at every point of potable water connection and use. Cross-Connections must be properly protected or eliminated.

How does contamination occur?

When you turn on a faucet, you expect the water to be as safe as when it left the water reservoir. However, certain hydraulic conditions left unprotected within your plumbing system may allow hazardous substances to enter and contaminate the drinking water in your home, or even the public water supply. Water normally flows in one direction to your faucet. However under certain conditions, water can actually flow backwards; this is known as Backflow. There are two situations that can cause Backflow: back-siphonage and back pressure.

Back-Siphonage: May occur due to a loss of pressure in the municipal water supply such as from a water main break.

Back Pressure: May occur when a source (such as a boiler) creates a greater pressure than the incoming water pressure.


Do...

- Keep the ends of hoses clear of all possible contaminants.
- Make sure dishwashers are installed with the proper "air gap" device.
- Verify hose bibb vacuum breaker on all threaded faucets around your home.
- Make sure water treatment devices such as water softeners have the proper "air gap", which is a minimum of one inch above the drain.

Don't...

- Submerge hoses in buckets, pools, tubs, sinks, ponds or automobile radiators.
- Use spray attachments without an approved backflow prevention device.
- Connect drain pipes from water softeners or other treatment systems directly to the sewer drain. Always be sure there is a one inch "air gap" separation.


ASSE #1011 Vacuum Breaker



In the Bathroom - Hand Held Shower

The hand held shower fixture is compliant if:



- When the shower hose head is hanging freely, it is at least 1 inch above the top of the flood level rim of the receptor (tub).
- Complies with ASSE # 1014.
- Has the ASME code 112.18.1 stamped on the handle.



In the Bathroom—Toilet Tanks

There are many unapproved toilet tank fill valve products sold at common retailers which do not meet the state plumbing code requirements for backflow prevention.

- Look for the ASSE #1002 Standard symbol on device and packaging.
- Replace any unapproved devices with an ASSE #1002 approved anti siphon ball-cock assembly. Average cost for this do-it-yourself-type device available at home improvement stores is \$8 to \$22.
- Verify overflow tube is one inch below critical level (CL) marking on device.



In the Kitchen

Hoses and water treatment devices may create a potential backflow hazard if not properly isolated with backflow prevention devices or methods.